



Life Science Laboratories, Inc.

Jack Mekeel
Cayuga Onondaga BOCES
1879 West Genesee Street Road
Auburn, NY 13021

Phone: (315) 253-0361

Laboratory Analysis Report Prepared For Cayuga Onondaga BOCES

LSL Project ID: 2103227

Receive Date/Time: 03/05/21 12:15

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667


LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:


Kristin E. Carpenter, Quality Staff

Date:



-- LABORATORY ANALYSIS REPORT --

Cayuga Onondaga BOCES Auburn, NY

Sample ID: COB 25 (Retest) LSL Sample ID: 2103227-001
Location:
Sampled: 03/05/21 6:19 Sampled By: JM
Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals Please refer to the next page			EPA 200.2			MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: COB 25 (Retest)

Lab ID: 2103227-001A
Collection Date: 03/05/21 6:19
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	03/17/21 17:26

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

- - LABORATORY ANALYSIS REPORT - -

Cayuga Onondaga BOCES Auburn, NY

Sample ID: COB 27 (Retest) LSL Sample ID: 2103227-002
Location:
Sampled: 03/05/21 6:21 Sampled By: JM
Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals Please refer to the next page			EPA 200.2			MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: COB 27 (Retest)

Lab ID: 2103227-002A
Collection Date: 03/05/21 6:21
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	03/17/21 19:07

Qualifiers: * Value may exceed the Acceptable Level
 E Value exceeds the instrument calibration range
 J Analyte detected below the PQL
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Practical Quantitation Limit (PQL)
 S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Cayuga Onondaga BOCES Auburn, NY

Sample ID: COB 57 (Retest) LSL Sample ID: 2103227-003
Location:
Sampled: 03/05/21 6:25 Sampled By: JM
Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals			EPA 200.2			
Please refer to the next page						MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: COB 57 (Retest)
Lab ID: 2103227-003A
Collection Date: 03/05/21 6:25
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0036	mg/L	03/17/21 19:09

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Cayuga Onondaga BOCES Auburn, NY

Sample ID: YMCA 1 LSL Sample ID: 2103227-004

Location:

Sampled: 03/05/21 6:42 Sampled By: JM

Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
-------------------	--------	-------	-------------	-----------	----------------------	------------------

(1) EPA 200.8, Rev. 5.4 Metals

EPA 200.2

Please refer to the next page

MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: YMCA 1
Lab ID: 2103227-004A
Collection Date: 03/05/21 6:42
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	03/17/21 17:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

- - LABORATORY ANALYSIS REPORT - -

Cayuga Onondaga BOCES Auburn, NY

Sample ID: CFL 1 Fountain LSL Sample ID: 2103227-005
Location:
Sampled: 03/05/21 6:55 Sampled By: JM
Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals Please refer to the next page			EPA 200.2			MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: *CFL Fountain*
Lab ID: 2103227-005A
Collection Date: 03/05/21 6:55
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	03/17/21 17:30

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Cayuga Onondaga BOCES Auburn, NY

Sample ID: CFL 2 Room 12 Sink LSL Sample ID: 2103227-006

Location:

Sampled: 03/05/21 6:56 Sampled By: JM

Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals			EPA 200.2			
Please refer to the next page						MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: CFL 2 Room 12 Sink

Lab ID: 2103227-006A
Collection Date: 03/05/21 6:56
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	03/17/21 17:32

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Cayuga Onondaga BOCES Auburn, NY

Sample ID: CFL 3 Room 17 Sink LSL Sample ID: 2103227-007

Location:

Sampled: 03/05/21 6:59 Sampled By: JM

Sample Matrix: PW

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals			EPA 200.2			
Please refer to the next page						MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: 2103227-Cayuga Onondaga BOCES
Location:
Matrix: PW

Client Sample ID: CFL 3 Room 17 Sink

Lab ID: 2103227-007A
Collection Date: 03/05/21 6:59
Date Received: 03/05/21 12:15

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 03/17/21 17:34

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

