



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Cayuga - Onondaga BOCES

Project Name: Regional Education Center

Jack Mekeel
1879 West Genesee Street Road
Auburn, NY 13021

Project / PO Number: N/A
Received: 05/30/2025
Reported: 06/30/2025

Analytical Testing Parameters

Client Sample ID: Culinary Arts East Prep Sink COB 1
Sample Matrix: Drinking Water
Lab Sample ID: J5F0380-01

Collected By: Jack Mekeel
Collection Date: 05/30/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2011	DLO

Client Sample ID: Culinary Arts West Prep Sink COB 2
Sample Matrix: Drinking Water
Lab Sample ID: J5F0380-02

Collected By: Jack Mekeel
Collection Date: 05/30/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2016	DLO

Client Sample ID: Bistro Sink COB 3
Sample Matrix: Drinking Water
Lab Sample ID: J5F0380-03

Collected By: Jack Mekeel
Collection Date: 05/30/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2017	DLO

Client Sample ID: Room 126 (Right) COB 4
Sample Matrix: Drinking Water
Lab Sample ID: J5F0380-04

Collected By: Jack Mekeel
Collection Date: 05/30/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2019	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 126 (Left) COB 5

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-05

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2021	DLO

Client Sample ID: Cafeteria COB 6

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-06

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2022	DLO

Client Sample ID: Room 132 COB 7

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-07

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0092	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2027	DLO

Client Sample ID: Room 133 COB 8

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-08

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2028	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 210 COB 9

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-09

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2030	DLO

Client Sample ID: Room 203 COB 10

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-10

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2031	DLO

Client Sample ID: Service Corridor 1 COB 11

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-11

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2033	DLO

Client Sample ID: Service Corridor 2 COB 12

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-12

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2036	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 304 COB 14

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-13

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2037	DLO

Client Sample ID: Room 322 - Nurses Office COB 15

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-14

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2039	DLO

Client Sample ID: Special ED Kitchen COB 16

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-15

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2040	DLO

Client Sample ID: Room 408 (1) COB 17

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-16

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2045	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 408 (2) COB18

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-17

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2046	DLO

Client Sample ID: Central Corridor (1A) COB 19

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-18

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2048	DLO

Client Sample ID: Central Corridor (1B) COB 20

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-19

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2050	DLO

Client Sample ID: Central Corridor (2) COB 21

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-20

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1553	06/16/25 2051	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: CTE Kitchen COB 22

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-21

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2059	DLO

Client Sample ID: Conference Room 1 COB23

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-22

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2103	DLO

Client Sample ID: Conference Room 2 COB 24

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-23

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2105	DLO

Client Sample ID: Conference Room 3 COB 25

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-24

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2106	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: East Wing Corridor (1) COB 26

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-25

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2108	DLO

Client Sample ID: East Wing Corridor (1A) COB 27

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-26

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2109	DLO

Client Sample ID: East Wing Corridor (2) COB 28

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-27

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2114	DLO

Client Sample ID: Room 501 (1) COB 29

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-28

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2115	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 501 (2) COB 30

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-29

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2117	DLO

Client Sample ID: Room 502 (1) COB 31

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-30

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2119	DLO

Client Sample ID: Room 502 (2) COB 32

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-31

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2120	DLO

Client Sample ID: Room 603 - Nurses Office COB 33

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-32

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2123	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 604 COB 34

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-33

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2125	DLO

Client Sample ID: Room 606 COB 35

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-34

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2126	DLO

Client Sample ID: Room 605 Interior COB 36

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-35

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2128	DLO

Client Sample ID: Room 605 Exterior COB 37

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-36

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2132	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 607 COB 38

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-37

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2134	DLO

Client Sample ID: Room 612 COB 39

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-38

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2135	DLO

Client Sample ID: Room 613 COB 40

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-39

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2137	DLO

Client Sample ID: Room 614 COB 41

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-40

Collected By: Jack Mekeel

Collection Date: 05/06/2025 6:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2139	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Room 615 COB 42

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-41

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2146	DLO

Client Sample ID: Room 621 COB 43

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-42

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2150	DLO

Client Sample ID: Room 620 COB 44

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-43

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2152	DLO

Client Sample ID: HERO COB 45

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-44

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2154	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Daycare 706 - Cold Faucet COB 46

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-45

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2155	DLO

Client Sample ID: Daycare 706 - Fountain COB 47

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-46

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2157	DLO

Client Sample ID: Daycare 705 - Cold Faucet COB 48

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-47

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2201	DLO

Client Sample ID: Daycare 705 - Fountain COB 49

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-48

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2203	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Daycare 711 Handsink COB 50

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-49

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2204	DLO

Client Sample ID: Daycare 711 Prep Sink COB 51

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-50

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2206	DLO

Client Sample ID: Daycare 701 COB 52

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-51

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2208	DLO

Client Sample ID: Daycare 702 COB 53

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-52

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2210	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Daycare 707 (1) COB 54

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-53

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2212	DLO

Client Sample ID: Daycare 707 (2) COB 55

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-54

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2214	DLO

Client Sample ID: District Office OPR COB 56

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-55

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2215	DLO

Client Sample ID: District Office Kitchen COB 57

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-56

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2220	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: District Office Assistant Superintendent COB 58

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-57

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2221	DLO

Client Sample ID: District Office Superintendents Office COB 59

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-58

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2223	DLO

Client Sample ID: District Office Corridor COB 60

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-59

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2224	DLO

Client Sample ID: District Office Reception COB 61

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-60

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1554	06/16/25 2226	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Board Room COB 62

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-61

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2233	DLO

Client Sample ID: Culinary COB 63

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-62

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2238	DLO

Client Sample ID: 126 Center COB 64

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-63

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2239	DLO

Client Sample ID: Cafeteria - Fountain COB 65

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-64

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2241	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: Cafeteria - Bottle Filler COB 66

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-65

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2242	DLO

Client Sample ID: 133 Hand Sink COB 67

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-66

Collected By: Jack Mekeel

Collection Date: 05/30/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2244	DLO

Client Sample ID: CFL1 - Fountain COB 68

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-67

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2248	DLO

Client Sample ID: CFL2 - Bottle Filler COB 69

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-68

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2250	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Client Sample ID: CFL3 - Cold Faucet COB 70

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-69

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2252	DLO

Client Sample ID: YMCA1 - Fountain COB 71

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-70

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2253	DLO

Client Sample ID: YMCA2 - Bottle Filler COB 72

Sample Matrix: Drinking Water

Lab Sample ID: J5F0380-71

Collected By: Jack Mekeel

Collection Date: 05/30/2025 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/16/25 1725	06/16/25 2255	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level

mg/L: Milligrams per Liter

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5F0380

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in dark ink that reads 'Shannon Weeks'.

Shannon Weeks

Customer Relationship Coordinator

Reported: 06/30/2025 15:20

Chain of Custody

Customer: Cayuga-Onondaga BOCES
 Contact: Jack Mekeel
 Project: LEAD TESTING

Sampled By: Jack Mekeel/AI Albring
 Sampler Phone #: 585-750-0709



School County: Cayuga
 School Type: BOCES
 School Name: Regional Educational Center
 School ID: 5051602
 Sampling Event Name:
 Building address: 1879 West Genesee Street Road, Auburn, NY 13021
 Building ID:


Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	DRAWING #	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Pass
										Date	Time	Date	Time	
1	COB1	WATER	FAUCET , COLD		Consumption		CULINARY ARTS EAST PREP SINK		1	5/29/25	21:00	5/30/25	0520	X
2	COB2	WATER	FAUCET , COLD		Consumption		CULINARY ARTS WEST PREP SINK		1	5/29/25	21:00	5/30/25	0520	X
3	COB3	WATER	FAUCET , COLD		Consumption		BISTRO SINK		1	5/29/25	21:00	5/30/25	0521	X
4	COB4	WATER	FAUCET , COLD		Consumption		ROOM 126 (RIGHT)		1	5/29/25	21:00	5/30/25	0525	X
5	COB5	WATER	FAUCET , COLD		Consumption		ROOM 126 (LEFT)		1	5/29/25	21:00	5/30/25	0525	X
6	COB6	WATER	FAUCET , COLD		Consumption		CAFETERIA		1	5/29/25	21:00	5/30/25	0529	X
7	COB7	WATER	FAUCET , COLD		Consumption		ROOM 132		1	5/29/25	21:00	5/30/25	0532	X
8	COB8	WATER	FAUCET , COLD		Consumption		ROOM 133		1	5/29/25	21:00	5/30/25	0533	X
9	COB9	WATER	FAUCET , COLD		Consumption		ROOM 210		1	5/29/25	21:00	5/30/25	0536	X
10	COB10	WATER	FAUCET , COLD		Consumption		ROOM 203		1	5/29/25	21:00	5/30/25	0535	X
11	COB11	WATER	FOUNTAIN		Consumption		SERVICE CORRIDOR 1		1	5/29/25	21:00	5/30/25	0538	X
12	COB12	WATER	FOUNTAIN		Consumption		SERVICE CORRIDOR 2		1	5/29/25	21:00	5/30/25	0539	X
13	xxx	xxx	xxxxx		Consumption		xxxxx			5/29/25	21:00	5/30/25	xxxxx	X
14	COB14	WATER	FAUCET , COLD		Consumption		ROOM 304		1	5/29/25	21:00	5/30/25	0543	X
15	COB15	WATER	FAUCET , COLD		Consumption		ROOM 322-NURSES OFFICE		1	5/29/25	21:00	5/30/25	0544	X
16	COB16	WATER	FAUCET , COLD		Consumption		SPECIAL ED. KITCHEN		1	5/29/25	21:00	5/30/25	0545	X
17	COB17	WATER	FAUCET , COLD		Consumption		ROOM 408 (1)		1	5/29/25	21:00	5/30/25	0547	X
18	COB18	WATER	FAUCET , COLD		Consumption		ROOM 408 (2)		1	5/29/25	21:00	5/30/25	0547	X

RLF
06/09/25

13
14
15
16
17

Cayuga - Onondaga BOCES
 PM: Shannon Weeks





Chain of Custody

18	19	COB19	WATER	FOUNTAIN		Consumption		CENTRAL CORRIDOR (1A)		1	5/29/25	21:00	5/30/25	0550	X
19	20	COB20	WATER	BOTTLE FILLER		Consumption		CENTRAL COORIDOR (1B)		1	5/29/25	21:00	5/30/25	0550	X
20	21	COB21	WATER	FOUNTAIN		Consumption		CENTRAL CORRIDOR (2)		1	5/29/25	21:00	5/30/25	0551	X
21	22	COB22	WATER	FAUCET , COLD		Consumption		CTE KITCHEN		1	5/29/25	21:00	5/30/25	0552	X
22	23	COB23	WATER	FAUCET , COLD		Consumption		CONFERENCE ROOM 1		1	5/29/25	21:00	5/30/25	0554	X
23	24	COB24	WATER	FAUCET , COLD		Consumption		CONFERENCE ROOM 2		1	5/29/25	21:00	5/30/25	0554	X
24	25	COB25	WATER	FAUCET , COLD		Consumption		CONFERENCE ROOM 3		1	5/29/25	21:00	5/30/25	0555	X
25	26	COB26	WATER	FOUNTAIN		Consumption		EAST WING CORRIDOR (1)		1	5/29/25	21:00	5/30/25	0556	X
26	27	COB27	WATER	BOTTLE FILLER		Consumption		EAST WING CORRIDOR (1A)		1	5/29/25	21:00	5/30/25	0556	X
27	28	COB 28	WATER	FOUNTAIN		Consumption		EAST WING CORRIDOR (2)		1	5/29/25	21:00	5/30/25	0556	X
28	29	COB 29	WATER	FAUCET , COLD		Consumption		ROOM 501 (1)		1	5/29/25	21:00	5/30/25	0557	X
29	30	COB30	WATER	FAUCET , COLD		Consumption		ROOM 501 (2)		1	5/29/25	21:00	5/30/25	0557	X
30	31	COB31	WATER	FAUCET , COLD		Consumption		ROOM 502 (1)		1	5/29/25	21:00	5/30/25	0558	X
31	32	COB32	WATER	FAUCET , COLD		Consumption		ROOM 502 (2)		1	5/29/25	21:00	5/30/25	0558	X
32	33	COB33	WATER	FAUCET , COLD		Consumption		ROOM 603 NURSES OFFICE		1	5/29/25	21:00	5/30/25	0601	X
33	34	COB34	WATER	FOUNTAIN		Consumption		ROOM 604		1	5/29/25	21:00	5/30/25	0603	X
34	35	COB35	WATER	FOUNTAIN		Consumption		ROOM 606		1	5/29/25	21:00	5/30/25	0603	X
35	36	COB36	WATER	FOUNTAIN		Consumption		ROOM 605 INTERIOR		1	5/29/25	21:00	5/30/25	0606	X
36	37	COB37	WATER	FOUNTAIN		Consumption		ROOM605 EXTERIOR		1	5/29/25	21:00	5/30/25	0606	X
37	38	COB38	WATER	FOUNTAIN		Consumption		ROOM 607		1	5/29/25	21:00	5/30/25	0606	X
38	39	COB39	WATER	FOUNTAIN		Consumption		ROOM 612		1	5/29/25	21:00	5/30/25	0609	X
39	40	COB40	WATER	FOUNTAIN		Consumption		ROOM 613		1	5/29/25	21:00	5/30/25	0610	X
40	41	COB41	WATER	FOUNTAIN		Consumption		ROOM 614		1	5/29/25	21:00	5/30/25	0611	X

Chain of Custody

41	42	COB42	WATER	FOUNTAIN		Consumption		ROOM 615		1	5/29/25	21:00	5/30/25	0612	X
42	43	COB43	WATER	FOUNTAIN		Consumption		ROOM 621		1	5/29/25	21:00	5/30/25	0612	X
43	44	COB44	WATER	FOUNTAIN		Consumption		ROOM 620		1	5/29/25	21:00	5/30/25	0613	X
44	45	COB45	WATER	FOUNTAIN		Consumption		HERO		1	5/29/25	21:00	5/30/25	0614	X
45	46	COB46	WATER	FAUCET , COLD		Consumption		DAYCARE 706		1	5/29/25	21:00	5/30/25	0516	X
46	47	COB47	WATER	FOUNTAIN		Consumption		DAYCARE 706		1	5/29/25	21:00	5/30/25	0517	X
47	48	COB48	WATER	FAUCET , COLD		Consumption		DAYCARE 705		1	5/29/25	21:00	5/30/25	0516	X
48	49	COB49	WATER	FOUNTAIN		Consumption		DAYCARE 705		1	5/29/25	21:00	5/30/25	0515	X
49	50	COB50	WATER	FAUCET , COLD		Consumption		DAYCARE 711 HANDSINK		1	5/29/25	21:00	5/30/25	0511	X
50	51	COB51	WATER	FAUCET , COLD		Consumption		DAYCARE 711 PREP SINK		1	5/29/25	21:00	5/30/25	0512	X
51	52	COB52	WATER	FAUCET , COLD		Consumption		DAYCCARE 701		1	5/29/25	21:00	5/30/25	0518	X
52	53	COB53	WATER	FAUCET , COLD		Consumption		DAYCARE 702		1	5/29/25	21:00	5/30/25	0519	X
53	54	COB54	WATER	FAUCET , COLD		Consumption		DAYCARE 707(1)		1	5/29/25	21:00	5/30/25	0514	X
54	55	COB55	WATER	FOUNTAIN		Consumption		DAYCARE 707(2)		1	5/29/25	21:00	5/30/25	0514	X
55	56	COB56	WATER	FAUCET , COLD		Consumption		DISTRICT OFFICE OPR		2	5/29/25	21:00	5/30/25	0503	X
56	57	COB57	WATER	FAUCET , COLD		Consumption		DISTRICT OFFICE KITCHEN		2	5/29/25	21:00	5/30/25	0504	X
57	58	COB58	WATER	FAUCET , COLD		Consumption		DISTRICT OFFICE ASSISTANT SUPERINTENDENT		2	5/29/25	21:00	5/30/25	0508	X
58	59	COB59	WATER	FAUCET , COLD		Consumption		DISTRICT OFFICE SUPERINTENDENTS OFFICE		2	5/29/25	21:00	5/30/25	0507	X
59	60	COB60	WATER	FOUNTAIN		Consumption		DISTRICT OFFICE CORRIDOR		2	5/29/25	21:00	5/30/25	0505	X
60	61	COB61	WATER	FAUCET , COLD		Consumption		DISTRICT OFFICE RECEPTION		2	5/29/25	21:00	5/30/25	0506	X
61	62	COB62	WATER	FAUCET , COLD		Consumption		BOARD ROOM		2	5/29/25	21:00	5/30/25	0505	X
62	63	COB63	WATER	FAUCET , COLD		Consumption		Culinary		1	5/29/25	21:00	5/30/25	0523	X
63	64	COB64	WATER	FAUCET , COLD		Consumption		126 CENTER		1	5/29/25	21:00	5/30/25	0527	X



Page 23 of 23

RIF
06/06/25

Cayuga - Onondaga BOCES
PM: Shannon Weeks

Received By (signature)	Date/Time
<i>Gene Fisher</i> 05/30/25	11:53
Received By (signature)	Date/Time

IR-2
17.8°C